

May 21, 2007

ANDERMAC INC
DANA DANIELS
2626 LIVE OAK HWY
YUBA CITY CA 95991

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: ANDERMAC INC
Product Name: HYGENIQUE WALL EQUIPMENT
Model Number(s): H-1B6, H-1B3 AND H-7B5A
Product File No: 20070252

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2012.

This approval supersedes the approval issued on April 8, 2002, under product file number 20020178.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020178.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be installed with the critical level of the vacuum breaker not less than six inches above the highest use of the hose tip of this product and with no positive shut off device downstream of the vacuum breaker.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov